

प्रपत्र संख्या २
(नियम ८ देखें)

कानपुर नगर निगम

6127

45

पुस्तक सं०

क्रम सं०

श्री - Mr. Seth M. R. Jaipuria School.
Nawamau, Kanpur - 208001 - मे प्राप्त हुए।

बिल संख्या

जाँच रजिस्टर की क्रम संख्या	भूगृहादि का नाम अथवा संख्या	भुगतान का विवरण	अवधि	धनराशि	
				रु०	पै०
		Water Testy fee (CSO) for one Sample		7000/-	
			योग	7000/-	

योग शब्दों में - Rs Seven thousand Only.

दिनांक: 24/06/2023

रोकड़िया

लेखा अधिकारी/राजस्व अधीक्षक

प्रशासक

जाँच और प्रमाण रजिस्टर

प्रभारी लिपिक

टिप्पणी: अनुज्ञप्ति (लाइसेन्सों) की दशा में यह रसीद अनुज्ञप्ति के स्थान पर प्रयुक्त नहीं की जा सकती और यह नगर निगम के अनुज्ञप्ति अस्वीकार कर देने के अधिकार पर कोई प्रतिकूल प्रभाव नहीं डालती।
अवैधानिक निर्माण के गिराये या हटाये जाने हेतु नगर निगम द्वारा की जाने वाली कार्यवाही पर इसका कोई प्रतिकूल प्रभाव नहीं पड़ेगा।

क.नि.पेस

Assistant Engineer of



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the M/S BETH M.R. JAIPURIA SCHOOL, NARAMAU
SURMERCIBLE (R.O.) KANPUR NAGAR

Sample taken from	-	-	-	-
Date of sample Drawn	-	-	26/06/2023	-
Date of analysis	-	-	26/06/2023	-
Physical Character	-	-	TRANSPARENT	-
P. H. Value	-	-	6.94	-
Free Ammonia Parts per 1000000	-	-	NIL	-
Alburinoid Ammonia Part per 1000000	-	-	NIL	-
Oxygen absorbed from pot. Permagnate in three hours at 37 C	-	-	0.0	-
Chloride Part per 1000000	-	-	7.0	-
Nitrates Parts per 1000000	-	-	NIL	-
Nitrates Parts per 1000000	-	-	NIL	-
Total solid part per 100000	-	-	110.0	-
Fixed solid Parts per 1000000	-	-	NLD	-
Volatils solid Parts per 100000	-	-	NLD	-
Appearance on ignition	-	-	NO CHARRING	-
Total hardness Parts per 1000000	-	-	70.00	-
Permanent hardness Parts per 1000000	-	-	-	-
Temporary hardness Parts per 1000000	-	-	-	-

K.N.N. PRESS

Remarks : 'POTABLE'

No. 315/S.A./Chem dated 30/06/2023
Copy forwarded for fovour or information to

M/S Beth M.R. Jaipuria School
Naramau, Kanpur

नगर स्वच्छता अधिकारी
नगर निगम
Nagar Swasthya Adhikari
Nagar Nigam Kanpur

ALKA SINGH
(Chemist)
Nagar Nigam Kanpur

2) M.S.A. Kanpur Nagar Nigam

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 315/SWA/Chem.

Dated : 30/06/2023

It is certified that an inspection team headed by Mrs. ALKA SINGH-CHEMIST (Name of Officer with Designation) From KANPUR NAGAR NIGAM (Name of Department/ Office) inspected the BETH M. R. JAIPURIA SCHOOL, NARAMAU, KANPUR (Name & Address of the School) on 26/06/2023 (Date of Inspection) checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintain hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

Signature with Seal :

Name :

Designation : CHEMIST - HEALTH

Assistant Engineer of
The Govt. Public Health Department (PHED)/
Authorised officer of the local Body

Name & Address of the office / Department:

To,
BETH M. R. JAIPURIA
SCHOOL, NARAMAU
KANPUR NAGAR



KANPUR NAGAR NIGAM

D.No: 315/SSA/Chem 30/06/2023

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from MS. SETH M. R. JAIPURIA SCHOOL, NARAYAN

Name & designation of the person collecting samples: ALKA SINGH - CHEMIST (HEALTH) KANPUR NAGAR

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count			Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS	
		at 37.c in 48 hours	at room temp return in 72 hours	Quantity of water put in each tube No of tubes put up	50ML 1	10 ML 5				1 MI 5
26/06/2023	SUBMERSIBLE	ZERO	ZERO	—	NCL	NCL	NCL	ZERO	NCL	'Good'

Copy for Information Forwarded to (1) Seth M. R. Jaipuria School, NARAYAN Kanpur

(2) N.S.A Kanpur Nagar Nigam.

ALKA SINGH
(Chemist)
Nagar Nigam Kanpur.

Handwritten signature and stamp of Alka Singh, Chemist, Nagar Nigam Kanpur.